

Zertifikat

Certificate



Zertifikat Nr. *Certificate No.*
R 50415923

Blatt *Sheet*
0001

Ihr Zeichen *Client Reference*
L.S.Q.

Unser Zeichen *Our Reference*
01-ZJM-50047608 003

Ausstellungsdatum *Date of Issue*
07.09.2018
(day/mo/yr)

Genehmigungsinhaber *License Holder*

Teco Electric & Machinery Co., Ltd.
156-2, Sung Chiang Rd.
Taipei 104
Taiwan

Fertigungsstätte *Manufacturing Plant*

030-0000461540

Prüfzeichen *Test Mark*



Type Approved
Safety
Regular Production
Surveillance

www.tuv.com
ID 1419061342

Geprüft nach *Tested acc. to*

EN 60947-2:2006+A1+A2

**Zertifiziertes Produkt (Geräteidentifikation)
*Certified Product (Product Identification)***

**Lizenzentgelte - Einheit
*License Fee - Unit***

Circuit Breaker (Moulded Case Circuit Breaker)

Type Designation : TDB-250N 5

Reference Temperature : +50°C

Utilization Category : A

Number of Poles : 2P Appearance

Rated Operation Voltage (Ue) : DC1000V

Rated Operation Current (Ie) : 63/80/100/125/140/160/180/200/
225/250A

Rated Service Short-circuit
Breaking Capacity(Ics) : 15kA

Rated Ultimate Short-circuit
Breaking Capacity (Icu) : 20kA

Rated Impulse Withstand
Voltage (Uimp) : 8kV

Rated Insulation Voltage(Ui) : 1000V

Degree of Protection : IP30

Over Current Release Type : Thermal magnetic

5

Dem Zertifikat liegt unsere Prüf- und Zertifizierungsordnung zugrunde und es bestätigt die Konformität des Produktes mit den oben genannten Standards und Prüfgrundlagen. Zusätzliche Anforderungen in Ländern, in denen das Produkt in Verkehr gebracht werden soll, müssen zusätzlich betrachtet werden. Die Herstellung des zertifizierten Produktes wird überwacht.

This certificate is based on our Testing and Certification Regulation and states the conformity of the product with the standards and testing requirements as indicated above. Any additional requirements in countries where the product is going to be marketed have to be considered additionally. The manufacturing of the certified product is subject to surveillance.

TÜV Rheinland LGA Products GmbH, Tillystraße 2, 90431 Nürnberg

Tel.: +49 221 806-1371 e-mail: cert-validity@de.tuv.com
Fax: +49 221 806-3935 http://www.tuv.com/safety

Zertifizierungsstelle



Jie Zhang