



Product Service

CERTIFICATE

No. B 004289 0001 Rev. 00

Holder of Certificate: **Teco Electric & Machinery Co., Ltd.**

Hu-Kou Plant No.15, Chung Hwa Rd., Hsinchu Industrial Park
303 Hsinchu
TAIWAN

Certification Mark:



Product:

Switches
Switch-Disconnecter for use in photovoltaic

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition the certification holder must not transfer the certificate to third parties. See also notes overleaf.

Test report no.: 701281721401-00

Valid until: 2021-09-26

Date, 2018-09-27

(Yi Zhu)



Product Service

CERTIFICATE

No. B 004289 0001 Rev. 00

Model(s): TDS-250N

Brand Name: TECO

Parameters:

Rated operational voltage:	DC1000V
Rated insulation voltage:	1000V
Conventional free air thermal current:	250A
Rated operational current:	250A
Rated short-time withstand current:	3kA/1s
Rated short-circuit making capacity:	3kA
Utilization category:	DC-23A, DC-PV2

Tested according to: EN 60947-1:2007/A2:2014
EN 60947-3:2009/A2:2015

Production Facility(ies): 083266