

表1 限用物質含有情況超出百分比含量基準值之標示

東元電機股份有限公司						
設備名稱：漏電斷路器， 型號（型式）：請見表2						
Equipment name Type designation (Type)						
單元Unit	限用物質及其化學符號 Restricted substances and its chemical symbols					
	鉛Lead (Pb)	汞Mercury (Hg)	鎘Cadmium (Cd)	六價鉻 Hexavalent chromium (Cr <sup>+6</sup> )	多溴聯苯 Polybrominated biphenyls (PBB)	多溴二苯醚 Polybrominated diphenyl ethers (PBDE)
外殼、把手、絕緣板	○	○	○	○	○	○
接點	○	○	—	○	○	○
內部機構及零件	○	○	○	○	○	○
電路板	—	○	○	○	○	○
螺絲、配件	○	○	○	○	○	○
備考1. “超出0.1 wt %”及“超出0.01 wt %”係指限用物質之百分比含量超出百分比含量基準值。 Note 1: “Exceeding 0.1 wt %” and “exceeding 0.01 wt %” indicate that the percentage content of the restricted substance exceeds the reference percentage value of presence condition.						
備考2. “○”係指該項限用物質之百分比含量未超出百分比含量基準值。 Note 2: “○” indicates that the percentage content of the restricted substance does not exceed the percentage of reference value of presence.						
備考3. “—”係指該項限用物質為排除項目。 Note 3: The “—” indicates that the restricted substance corresponds to the exemption.						

表2 適用機種的型式與系列型式

TLB-50E1	型 式	TLB-50E1 1P+N 50AF; In:15/20/30/40/50A;I Δ n:15/30/100/300/500mA; Icu:5kA/ 110V,5kA/ 220V
	系列型式	TLB-50E1 2P 50AF; In:15/20/30/40/50A;I Δ n:15/30/100/300/500mA;Icu:5kA/ 220V
TLB-50E2	型 式	TLB-50E2 1P+N 50AF; In:15/20/30/40/50A;I Δ n:15/30/100/300/500mA; Icu:10kA/ 110V,5kA/ 220V
	系列型式	TLB-50E2 2P 50AF; In:15/20/30/40/50A;I Δ n:15/30/100/300/500mA;Icu:10kA/ 220V
TLB-50E3	型 式	TLB-50E3 1P+N 50AF; In:15/20/30/40/50A;I Δ n:15/30/100/300/500mA; Icu:15kA/ 110V,10kA/220V
	系列型式	TLB-50E3 2P 50AF; In:15/20/30/40/50A;I Δ n:15/30/100/300/500mA;Icu:15kA/ 220V