

表1 限用物質含有情況超出百分比含量基準值之標示

東元電機股份有限公司						
設備名稱：無熔線斷路器， 型號（型式）：請見表2						
Equipment name		Type designation (Type)				
單元Unit	限用物質及其化學符號					
	Restricted substances and its chemical symbols					
	鉛Lead (Pb)	汞Mercury (Hg)	鎘Cadmium (Cd)	六價鉻 Hexavalent chromium (Cr ⁺⁶)	多溴聯苯 Polybrominated biphenyls (PBB)	多溴二苯醚 Polybrominated diphenyl ethers (PBDE)
外殼、把手、消弧側板	○	○	○	○	○	○
接點	○	○	○	○	○	○
內部機構及零件	—	○	○	○	○	○
螺絲、配件	○	○	○	○	○	○
備考1. “超出0.1 wt %” 及 “超出0.01 wt %” 係指限用物質之百分比含量超出百分比含量基準值。 Note 1: “Exceeding 0.1 wt %” and “exceeding 0.01 wt %” indicate that the percentage content of the restricted substance exceeds the reference percentage value of presence condition.						
備考2. “○” 係指該項限用物質之百分比含量未超出百分比含量基準值。 Note 2: “○” indicates that the percentage content of the restricted substance does not exceed the percentage of reference value of presence.						
備考3. “—” 係指該項限用物質為排除項目。 Note 3: The “-” indicates that the restricted substance corresponds to the exemption.						

表2 適用機種的型式與系列型式

TO-150E	型 式	TO-150E 1P Ui:690VAC 60Hz 150AF (150A) Icu:230VAC/15kA , Ics:230VAC/7.5kA
	系列型式	無