

# 自願性產品驗證證書

Certificate of the Voluntary Product Certification



證書號碼： V412040240242號99

Certificate No.

茲據 東元電機股份有限公司湖口廠 申請自願性產品驗證，  
經審查結果符合規定，准予並使用產品驗證標誌及識別號碼：  
其登載事項如下：

The application made by TECO ELECTRIC & MACHINERY CO., for Voluntary Product  
Certification has been reviewed and found to be in compliance with related regulations.  
Therefore, registration is granted with the Certification Mark and the Identification  
No. V41024 Details of the registration are as follows:



申請人： 東元電機股份有限公司湖口廠  
Applicant

地 址： 新竹縣湖口鄉鳳山村中華路15號  
Address

生產廠場： 東元電機股份有限公司湖口廠  
Factory

廠 址： 新竹縣湖口鄉鳳山村中華路15號  
Factory address

產品種類名稱： 大容量無熔線斷路器(交流電壓600V以下、額定電流超過800A、啟斷容量超  
Type/name of product 過220V/50kA、380V/30kA、440V/25kA、600V/20kA)

中文名稱： 無熔線斷路器  
Chinese name

英文名稱： MOLD CASE CIRCUIT BREAKER  
English name

型 式： TCB-800H2 3P/4P 800AF 60Hz In:500/600/630/700/800A;Icu/Ics:AC220V  
Type 100 /50kA, AC380V 65/33kA, AC440V 50/25kA

系列產品： 空白  
Series of type

驗證標準： CNS14816-2 (93年版)  
Standards

## 標準檢驗局發證

This certificate shall be issued by the BSMI

本證書以電子文件行之，所載內容若有不符之處，以標準檢驗局系統登錄資料為主，查詢證書資料網址：  
<https://civil.bsmi.gov.tw>

|                   |      |        |    |         |    |       |
|-------------------|------|--------|----|---------|----|-------|
| 核可日期：中華民國         | 112  | 年      | 08 | 月       | 11 | 日     |
| Registration date | 2023 | (year) | 08 | (month) | 11 | (day) |
| 本證書有效期限至          | 118  | 年      | 08 | 月       | 10 | 日     |
| Expiration Date   | 2029 | (year) | 08 | (month) | 10 | (day) |
| 發證日期：中華民國         | 115  | 年      | 07 | 月       | 01 | 日     |
| Date of issue     | 2026 | (year) | 07 | (month) | 01 | (day) |



註：次年度自願性產品驗證年費繳納期限為當年11月30日，逾期未繳納者，經限期繳納屆期  
未繳納，即依自願性產品驗證實施辦法第21條第8款規定廢止產品驗證，並自次年度1月1日  
起生效。

列印序號:1451504244110072044