

自願性產品驗證證書

Certificate of the Voluntary Product Certification



證書號碼： V311033030061號A1

Certificate No.

茲據 東元電機股份有限公司

申請自願性產品驗證，

經審查結果符合規定，准予並使用產品驗證標誌及識別號碼：

其登載事項如下：

The application made by _____ for Voluntary Product Certification has been reviewed and found to be in compliance with related regulations. Therefore, registration is granted with the Certification Mark and the Identification No. _____ Details of the registration are as follows:



申請人：東元電機股份有限公司
Applicant

地址：臺北市南港區三重路19-9號5樓
Address

生產廠場：東元電機股份有限公司湖口廠
Factory

廠址：新竹縣湖口鄉鳳山村中華路15號
Factory address

產品種類名稱：大容量無熔線斷路器(限檢驗交流電壓600V以下，額定電流超過800A或短路容量超過220V/50kA、380V/30kA、440V/25kA及600V/20kA)
Type/name of product

中文名稱：空氣斷路器
Chinese name

英文名稱：Air Circuit Breaker
English name

型式：TAB-3200 3P/4P In:2000/2500/3200A, Ui:1kV, Uimp:12kV, Icu/Ics:65/65kA at 600V;100/80kA at 380V, Icw:50kA 1s at 600V;65kA 1s at 380V
Type

系列產品：空白
Series of type

驗證標準：CNS14816-2 (93年版)
Standards

標準檢驗局發證

This certificate shall be issued by the BSMI

本證書以電子文件行之，所載內容若有不符之處，以標準檢驗局系統登錄資料為主，查詢證書資料網址：

<https://civil.bsmi.gov.tw>

核可日期：中華民國 111 年 06 月 06 日
Registration date 2022 (year) 06 (month) 06 (day)

本證書有效期限至 114 年 06 月 05 日
Expiration Date 2025 (year) 06 (month) 05 (day)

發證日期：中華民國 113 年 07 月 04 日
Date of issue 2024 (year) 07 (month) 04 (day)



註：次年度自願性產品驗證年費繳納期限為當年11月30日，逾期未繳納者，經限期繳納屆期未繳納，即依自願性產品驗證實施辦法第21條第8款規定廢止產品驗證，並自次年度1月1日起生效。

列印序號:1311831073140070096