

# 自願性產品驗證證書

Certificate of the Voluntary Product Certification



證書號碼： V311033030061號00

Certificate No.

茲據 東元電機股份有限公司

申請自願性產品驗證，

經審查結果符合規定，准予並使用產品驗證標誌及識別號碼：  
其登載事項如下：



The application made by \_\_\_\_\_ for Voluntary Product Certification has been reviewed and found to be in compliance with related regulations. Therefore, registration is granted with the Certification Mark and the Identification No. \_\_\_\_\_ Details of the registration are as follows:

申請人：東元電機股份有限公司  
Applicant

地址：臺北市南港區三重路19-9號5樓  
Address

生產廠場：東元電機股份有限公司湖口廠  
Factory

廠址：新竹縣湖口鄉鳳山村中華路15號  
Factory address

產品種類名稱：大容量無熔線斷路器(限檢驗交流電壓600V以下，額定電流超過800A或短路容量超過220V/50kA、380V/30kA、440V/25kA及600V/20kA)  
Type/name of product

中文名稱：空氣斷路器  
Chinese name

英文名稱：Air Circuit Breaker  
English name

型式：TAB-3200 3P/4P  
Type In:2000/2500/3200A, Ui:1kV, Uimp:12kV, Icu/Ics:100/80kA at 380V, Icw:65kA 1s at 380V

系列產品：空白  
Series of type

驗證標準：CNS14816-2 (93年版)  
Standards

## 標準檢驗局發證

This certificate shall be issued by the BSMI

本證書以電子文件行之，所載內容若有不符之處，以標準檢驗局系統登錄資料為主，查詢證書資料網址：  
<https://civil.bsmi.gov.tw>

核可日期：中華民國	111	年	06	月	06	日
Registration date	2022	(year)	06	(month)	06	(day)
本證書有效期限至	114	年	06	月	05	日
Expiration Date	2025	(year)	06	(month)	05	(day)
發證日期：中華民國	111	年	04	月	29	日
Date of issue	2022	(year)	04	(month)	29	(day)



註：次年度自願性產品驗證年費繳納期限為當年11月30日，逾期未繳納者，經限期繳納屆期未繳納，即依自願性產品驗證實施辦法第21條第8款規定廢止產品驗證，並自次年度1月1日起生效。