

表1 限用物質含有情況超出百分比含量基準值之標示

東元電機股份有限公司						
設備名稱：漏電斷路器(RCBO)，型號（型式）：請見表2						
Equipment name		Type designation (Type)				
單元Unit	限用物質及其化學符號 Restricted substances and its chemical symbols					
	鉛Lead (Pb)	汞Mercury (Hg)	鎘Cadmium (Cd)	六價鉻 Hexavalent chromium (Cr ⁺⁶)	多溴聯苯 Polybrominated biphenyls (PBB)	多溴二苯醚 Polybrominated diphenyl ethers (PBDE)
外殼、把手、絕緣板	○	○	○	○	○	○
接點	○	○	○	○	○	○
內部機構及零件	○	○	○	○	○	○
電路板	—	○	○	○	○	○
螺絲、配件	○	○	○	○	○	○
備考1. “超出0.1 wt %” 及 “超出0.01 wt %” 係指限用物質之百分比含量超出百分比含量基準值。 Note 1: “Exceeding 0.1 wt %” and “exceeding 0.01 wt %” indicate that the percentage content of the restricted substance exceeds the reference percentage value of presence condition.						
備考2. “○” 係指該項限用物質之百分比含量未超出百分比含量基準值。 Note 2: “○” indicates that the percentage content of the restricted substance does not exceed the percentage of reference value of presence.						
備考3. “—” 係指該項限用物質為排除項目。 Note 3: The “—” indicates that the restricted substance corresponds to the exemption.						

表2 適用機種の型式與系列型式

TLB-100L1A	型 式	TLB-100L1A 4P 60Hz 100AF;Ue:AC 220V,380V,440V ; In:15A,20A,30A,40A,50A,60A,63A,75A,100A; I△n: 0.03A / 0.1A / 0.3A高速切换型, 0.2A / 0.3A / 0.5A高速切换型; Icu:10kA at 220V,7.5kA at 380V,7.5kA at 440V; Isu:2kA at 440V
	系列型式	TLB-100L1A 3P 60Hz 100AF;Ue:AC 220V,380V,440V ; In:15A,20A,30A,40A,50A,60A,63A,75A,100A; I△n: 0.03A / 0.1A / 0.3A高速切换型, 0.2A / 0.3A / 0.5A高速切换型; Icu:10kA at 220V,7.5kA at 380V,7.5kA at 440V; Isu:2kA at 440V
TLB-100L2A	型 式	TLB-100L2A 4P 60Hz 100AF;Ue:AC 220V,380V,440V ; In:15A,20A,30A,40A,50A,60A,63A,75A,100A; I△n: 0.03A / 0.1A / 0.3A高速切换型, 0.2A / 0.3A / 0.5A高速切换型; Icu:15kA at 220V,10kA at 380V,7.5kA at 440V; Isu:2kA at 440V
	系列型式	TLB-100L2A 3P 60Hz 100AF;Ue:AC 220V,380V,440V ; In:15A,20A,30A,40A,50A,60A,63A,75A,100A; I△n: 0.03A / 0.1A / 0.3A高速切换型, 0.2A / 0.3A / 0.5A高速切换型; Icu:15kA at 220V,10kA at 380V,7.5kA at 440V; Isu:2kA at 440V