

表1 限用物質含有情況超出百分比含量基準值之標示

東元電機股份有限公司						
設備名稱：無熔線斷路器(附漏電保護功能)，型號（型式）：請見表2 Equipment name Type designation (Type)						
單元Unit	限用物質及其化學符號 Restricted substances and its chemical symbols					
	鉛Lead (Pb)	汞Mercury (Hg)	鎘Cadmium (Cd)	六價鉻 Hexavalent chromium (Cr ⁺⁶)	多溴聯苯 Polybrominated biphenyls (PBB)	多溴二苯醚 Polybrominated diphenyl ethers (PBDE)
外殼、把手、絕緣板	○	○	○	○	○	○
接點	○	○	○	○	○	○
內部機構及零件	—	○	○	超出0.1wt%	○	○
電路板	超出0.1wt%	○	○	○	○	○
螺絲、配件	○	○	○	○	○	○
備考1. “超出0.1 wt %”及“超出0.01 wt %”係指限用物質之百分比含量超出百分比含量基準值。 Note 1: “Exceeding 0.1 wt %” and “exceeding 0.01 wt %” indicate that the percentage content of the restricted substance exceeds the reference percentage value of presence condition. 備考2. “○”係指該項限用物質之百分比含量未超出百分比含量基準值。 Note 2: “○” indicates that the percentage content of the restricted substance does not exceed the percentage of reference value of presence. 備考3. “—”係指該項限用物質為排除項目。 Note 3: The “—” indicates that the restricted substance corresponds to the exemption.						

表2 適用機種的型式與系列型式

TLB-250E	型 式	TLB-250E 3P 250AF 60Hz,AT:125/150/175/200/225/250A; I△n:30mA固定型, 100/200/300mA調整型; Icu/Ics:220VAC 30/15kA, 380VAC 22/11kA, 440VAC 15/7.5kA
	系列型式	
TLB-250S	型 式	TLB-250S 3P 60Hz 250AF;Ue:AC 220V,380V,440V ; In:125A,150A,175A,200A,225A,250A; I△n:30mA固定型,100/200/300mA 切換型; 5I△n動作時間:0.04秒以內;Icu:50kA at 220V,30kA at 380V,25kA at 440V; Ics:25kA at 220V,15kA at 380V,13kA at 440V;Isu:6.3kA at 254V
	系列型式	TLB-250S 4P 60Hz 250AF;Ue:AC 220V,380V,440V ;In:125/150/175/200/225/250A; I△n:30mA固定型,100/200/300mA切換型; Icu/Ics:220VAC 50/25kA, 380VAC 30/15kA, 440VAC 25/13kA ; Isu:6.3kA at 254V