

經濟部標準檢驗局
商品型式認可證書

Certificate of the Type Approval of Product
Bureau of Standards, Metrology and Inspection, Ministry of Economic Affairs



證書號碼： TA095410240106 號 Y5
Certificate

茲據東元電機股份有限公司湖口廠
經審查結果符合規定，准予認可，並使用檢驗標識
及識別號碼： T41024 。其認可事項如下：

申請型式認可，



The application made by TECO ELECTRIC & MACHINERY CO.,LTD.HU-KOU PLANT for Type Approval of Product
has been reviewed and found to be in compliance with related regulations. Therefore, approval is granted with the Certification Mark
and Identification No. T41024. Details of the approval are as follows:



申請人：東元電機股份有限公司湖口廠

Applicant

地址：新竹縣湖口鄉鳳山村中華路15號

Address

產品種類名稱：

Type/name of

一、商品分類號列： 8536.20.49.00.6

C. C. C Code

二、中文名稱： 無熔線斷路器

Chinese name

三、英文名稱： MOLDED CASE CIRCUIT BREAKER

English name

四、型式： NC 1P Ui:500VAC 50/60Hz

Type

63AF(C0.5/C1/C2/C3/C4/C6/C10/C16/C20/C25/C32/C40/C50/C63)
Icn:10kA at 230V(1P), 10kA at 380V(2P, 3P); Ics:7.5kA at
230V(1P), 7.5kA at 380V(2P, 3P)

五、系列型式： 詳如附表

Series Type

六、依據標準/日期： IEC60898 (2003年版)、CNS14985-1 (95年版)、符合CNS 15663
第5節「含有標示」規定 (102年版)

Standards / Date

標準檢驗局發證

This certificate shall be issued by the BSMI

本證書以電子文件行之，所載內容若有不符之處，以標準檢驗局系統登錄資料為主，查詢證書資料
網址：<https://civil.bsmi.gov.tw>

認可日期：中華民國 095 年 10 月 24 日

Approval Date 2006 (year) 10 (month) 24 (day)

本證書有效期限至 116 年 10 月 23 日

Expiration Date 2027 (year) 10 (month) 23 (day)

發證日期：中華民國 113 年 09 月 03 日

Date of issue 2024 (year) 09 (month) 03 (day)



取得本證書後，商品仍需每批向經濟部標準檢驗局報驗並取得合格證書後，始完成檢驗程序。

經濟部標準檢驗局
商品型式認可證書

Certificate of the Type Approval of Product
Bureau of Standards, Metrology and Inspection, Ministry of Economic Affairs

證書號碼： TA095410240106 號 Y5
Certificate No.

系列型式： NC 2P U_i :500VAC 50/60Hz
Series of the type 63AF(C0.5/C1/C2/C3/C4/C6/C10/C16/C20/C25/C32/C40/C50/C63) I_{cn} :10kA at
230V(1P), 10kA at 380V(2P, 3P); I_{cs} :7.5kA at 230V(1P), 7.5kA at 380V(2P, 3P)

NC 3P U_i :500VAC 50/60Hz
63AF(C0.5/C1/C2/C3/C4/C6/C10/C16/C20/C25/C32/C40/C50/C63) I_{cn} :10kA at
230V(1P), 10kA at 380V(2P, 3P); I_{cs} :7.5kA at 230V(1P), 7.5kA at 380V(2P, 3P)

(以下空白)

